



Testing. Advising. Assuring.

EWFA CERTIFICATE OF TEST	CERTIFICATE No : SFC 2581501.1	Page 1 of 1
---------------------------------	---------------------------------------	--------------------

Report Sponsor	Certificate Issue Date
NRG Building Systems Factory 4, 32-38 Dover Drive, West Burleigh QLD, 4220, Australia.	6/02/2012



Introduction
The element of construction described below was tested by this laboratory on behalf of the test sponsor in accordance with the stated test standard and achieved the results stated below. Refer to the referenced test report for further information.

Referenced Reports	Report Date	Test Standard
EWFA 2581501.1	31/05/11	AS1530.8.1-2007

Description of Tested Specimen
The test assembly comprised a nominal 3000 mm wide x 3000 mm high x 211 mm thick wall system that incorporated a 2000mm wide x 250mm deep recess formed within the central region of the wall. The wall system consisted of a 90x45 timber stud frame, incorporating an 800mm x 800mm timber reveal window a non-combustible sill and an eaves detail. The unexposed side was faced with 10mm Gyprock plasterboard while the exposed side had a 10mm Rockcote PM100 QRender over 73mm Greenboard™ foam cladding.

Test Results			
Crib class	A	Peak heat flux	29 kW/m ²
Test Result		BAL: A-29	

Notes
THIS CERTIFICATE IS PROVIDED FOR GENERAL INFORMATION ONLY AND DOES NOT COMPLY WITH THE REGULATORY REQUIREMENTS FOR EVIDENCE OF COMPLIANCE.
Reference should be made to the relevant test report to determine the applicability of the test result to a proposed installation. The results of these fire tests may be used to assess fire hazard, but it should be recognised that a single test method will not provide a full assessment of fire hazard under all conditions.

TESTING AUTHORITY	Exova Warringtonfire Aus Pty Ltd	
Address	PO Box 4282 DANDENONG SOUTH VIC 3164 Unit 2, 409-411 Hammond Road, DANDENONG VIC 3175	
Phone / Fax	+61 (0) 3 9767 1066 / +61 (0) 3 9767 1001	
ABN	81 050 241 524	
Email / Home Page	www.exova.com	
Authorisation	Prepared By:  C. M. McLean	Reviewed By:  K. G. Nicholls